

**Chapter 6
List of Figures**

Figure 6.2-1 A Break in a Feedwater Line.....6.2-148

Figure 6.2-2 Feedwater Line Break—RPV Side Break Area6.2-149

Figure 6.2-3 Feedwater Line Break Flow—Feedwater System Side of Break.....6.2-150

Figure 6.2-4 Feedwater Line Break Flow Enthalpy—Feedwater System Side of Break6.2-151

Figure 6.2-5 Lower Drywell Air Transfer Percentage for Model Assumption Versus Actual Case6.2-152

Figure 6.2-6 Pressure Response of the Primary Containment for Feedwater Line Break6.2-153

Figure 6.2-7 Temperature Response of the Primary Containment for Feedwater Line Break6.2-154

Figure 6.2-8 Temperature Time History After a Feedwater Line Break6.2-155

Figure 6.2-8a Pressure Time History After a Feedwater Line Break6.2-156

Figure 6.2-9 ABWR Main Steamlines with a Break6.2-157

Figure 6.2-10 MSLB Area as a Function of Time6.2-158

Figure 6.2-11 Feedwater Specific Enthalpy as a Function of Integrated Feedwater Flow Mass6.2-159

Figure 6.2-12 Pressure Time History for MSLB with Two-Phase Blowdown Starting When the RPV Collapsed Level Reaches the Main Steam Nozzle6.2-160

Figure 6.2-13 Temperature Time History for MSLB with Two-Phase Blowdown Starting When the RPV Collapsed Level Reaches the Main Steam Nozzle.....6.2-161

Figure 6.2-14 Pressure Time History for MSLB with Two-Phase Blowdown Starting at One Second6.2-162

Figure 6.2-15 Temperature Time History for MSLB with Two-Phase Blowdown Starting at One Second6.2-163

Figure 6.2-16 Not Used.....6.2-164

Figure 6.2-17 Differential Pressures in Wetwell and Drywell Relative to Reactor Building for Vacuum Breaker Size of .77 m².....6.2-165

Figure 6.2-18 Differential Pressures in Wetwell and Drywell Relative to Reactor Building with Wetwell Spray for Vacuum Breaker Size of .77 m².....6.2-166

Figure 6.2-19 Temperature and Pressure Time Histories in the Containment During Stuck Open Relief Valve Transient.....6.2-167

Figure 6.2-20 Not Used.....6.2-168

List of Figures (Continued)

Figure 6.2-21	Not Used.....	6.2-169
Figure 6.2-22	Not Used.....	6.2-170
Figure 6.2-23	Break Flow Rate and Specific Enthalpy for the Feedwater Line Break Flow Coming from the RPV Side	6.2-171
Figure 6.2-24	Break Flow Rate and Specific Enthalpy for the Main Steamline Break with Two-Phase Blowdown Starting When the Collapsed Water Level Reaches the Steam Nozzle.....	6.2-172
Figure 6.2-25	Break Flow Rate and Specific Enthalpy for the Main Steamline Break with Two-Phase Blowdown Starting at One Second	6.2-173
Figure 6.2-26	ABWR Containment Boundary Nomenclature.....	6.2-174
Figure 6.2-27	Three Basic Types of Leakage Paths	6.2-175
Figure 6.2-28	Not Used.....	6.2-176
Figure 6.2-29	Not Used.....	6.2-176
Figure 6.2-30	Not Used.....	6.2-176
Figure 6.2-31	Not Used.....	6.2-176
Figure 6.2-32	Not Used.....	6.2-176
Figure 6.2-33	Not Used.....	6.2-176
Figure 6.2-34	Not Used.....	6.2-176
Figure 6.2-35	Not Used.....	6.2-176
Figure 6.2-36	Not Used.....	6.2-176
Figure 6.2-37	Secondary Containment Schematic Flow Diagram	6.2-177
Figure 6.2-38	Plant Requirements, Group Classification and Containment Isolation Diagram (Sheets 1 – 2).....	6.2-178
Figure 6.2-39	Atmospheric Control System P&ID.....	6.2-179
Figure 6.2-40	Flammability Control System P&ID.....	6.2-180
Figure 6.2-41	Hydrogen and Oxygen Concentrations in Containment After Design Basis LOCA	6.2-181
Figure 6.2-42	Allowable Steam Bypass Leakage Capacity	6.2-182
Figure 6.2-43	Typical Pressure Fluctuation Due to CO.....	6.2-183

List of Figures (Continued)

Figure 6.2-44 Typical Pressure Fluctuation Due To CH6.2-184

Figure 6.2-45 Quencher Bubble Pressure Time History6.2-185

Figure 6.2-46 Containment Monitoring System P&ID.....6.2-186

Figure 6.3-1 High Pressure Core Flooder System (HPCF) PFD6.3-37

Figure 6.3-2 Core Loading Map Used for Response Analyses.....6.3-38

Figure 6.3-3 Not Used.....6.3-39

Figure 6.3-4 Pressure Versus High Pressure Core Flooder Flow (Per System) Used in LOCA
Analysis6.3-40

Figure 6.3-5 Pressure Versus Reactor Core Isolation Cooling Flow Used in LOCA
Analysis6.3-41

Figure 6.3-6 Pressure Versus Low Pressure Flooder Flow (Per System) Used in LOCA
Analysis6.3-42

Figure 6.3-7 High Pressure Core Flooder System (HPCF) P&ID (Sheets 1-2).....6.3-43

Figure 6.3-8 Not Used.....6.3-44

Figure 6.3-9 Not Used.....6.3-44

Figure 6.3-10 Minimum Water Level Outside Shroud Versus Break Area.....6.3-45

Figure 6.3-11 Normalized Core Power Versus Time For Loss-of-Coolant Accident
Analysis6.3-46

Figure 6.3-12 Normalized Core Flow Following a Main Steamline Break Inside Containment,
HPCF Diesel Generator Failure6.3-47

Figure 6.3-13 Minimum Critical Power Ratio Following a Main Steamline Break Inside Containment,
HPCF Diesel Generator Failure6.3-47

Figure 6.3-14 Water Level in Fuel Channels Following a Main Steamline Break Inside Containment,
HPCF Diesel Generator Failure6.3-48

Figure 6.3-15 Water Level Inside Shroud Following a Main Steamline Break Inside Containment,
HPCF Diesel Generator Failure6.3-48

Figure 6.3-16 Water Level Outside Shroud Following a Main Steamline Break Inside Containment,
HPCF Diesel Generator Failure6.3-49

Figure 6.3-17 Vessel Pressure Following a Main Steamline Break Inside Containment,
HPCF Diesel Generator Failure6.3-49

List of Figures (Continued)

Figure 6.3-18	Flow Out of Vessel Following a Main Steamline Break Inside Containment, HPCF Diesel Generator Failure	6.3-50
Figure 6.3-19	Flow Into Vessel Following a Main Steamline Break Inside Containment, HPCF Diesel Generator Failure	6.3-50
Figure 6.3-20	Peak Cladding Temperature Following a Main Steamline Break Inside Containment, HPCF Diesel Generator Failure	6.3-51
Figure 6.3-21	Normalized Core Flow Following a Feedwater Line Break, HPCF Diesel Generator Failure	6.3-51
Figure 6.3-22	Minimum Critical Power Ratio Following a Feedwater Line Break, HPCF Diesel Generator Failure	6.3-52
Figure 6.3-23	Water Level in Fuel Channels Following a Feedwater Line Break, HPCF Diesel Generator Failure	6.3-52
Figure 6.3-24	Water Level Inside Shroud Following a Feedwater Line Break, HPCF Diesel Generator Failure	6.3-53
Figure 6.3-25	Water Level Outside Shroud Following a Feedwater Line Break, HPCF Diesel Generator Failure	6.3-53
Figure 6.3-26	Vessel Pressure Following a Feedwater Line Break, HPCF Diesel Generator Failure	6.3-54
Figure 6.3-27	Flow Out of Vessel Following Line Break, HPCF Diesel Generator Failure.....	6.3-54
Figure 6.3-28	Flow Into Vessel Following a Feedwater Line Break, HPCF Diesel Generator Failure	6.3-55
Figure 6.3-29	Peak Cladding Temperature Following a Feedwater Line Break, HPCF Diesel Generator Failure	6.3-55
Figure 6.3-30	Water Level in Fuel Channels Following an RHR Shutdown Suction Line Break, HPCF Diesel Generator Failure	6.3-56
Figure 6.3-31	Water Level Inside Shroud Following an RHR Shutdown Suction Line Break, HPCF Diesel Generator Failure	6.3-56
Figure 6.3-32	Water Level Outside Shroud Following an RHR Shutdown Suction Line Break, HPCF Diesel Generator Failure	6.3-57
Figure 6.3-33	Vessel Pressure Following an RHR Shutdown Suction Line Break, HPCF Diesel Generator Failure	6.3-57
Figure 6.3-34	Flow Out of Vessel Following an RHR Shutdown Suction Line Break, HPCF Diesel Generator Failure	6.3-58

List of Figures (Continued)

Figure 6.3-35	Flow Into Vessel Following an RHR Shutdown Suction Line Break, HPCF Diesel Generator Failure	6.3-58
Figure 6.3-36	Peak Cladding Temperature Following an RHR Shutdown Suction Line, HPCF Diesel Generator Failure	6.3-59
Figure 6.3-37	Water Level in Fuel Channels Following an RHR/LPFL Injection Line Break, HPCF Diesel Generator Failure	6.3-59
Figure 6.3-38	Water Level Inside Shroud Following an RHR/LPFL Injection Line Break, HPCF Diesel Generator Failure	6.3-60
Figure 6.3-39	Water Level Outside Shroud Following an RHR/LPFL Injection Line Break, HPCF Diesel Generator Failure	6.3-60
Figure 6.3-40	Vessel Pressure Following an RHR/LPFL Injection Line Break, HPCF Diesel Generator Failure	6.3-61
Figure 6.3-41	Flow Out of Vessel Following an RHR/LPFL Injection Line Break, HPCF Diesel Generator Failure	6.3-61
Figure 6.3-42	Flow Into Vessel Following an RHR/LPFL Injection Line Break, HPCF Diesel Generator Failure	6.3-62
Figure 6.3-43	Peak Cladding Temperature Following an RHR/LPFL Injection Line Break, HPCF Diesel Generator Failure	6.3-62
Figure 6.3-44	Normalized Core Flow Following a Core Flooder Line Break, HPCF Diesel Generator Failure	6.3-63
Figure 6.3-45	Minimum Critical Power Ratio Following a Core Flooder Line Break, HPCF Diesel Generator Failure	6.3-63
Figure 6.3-46	Water Level in Fuel Channels Following a Core Flooder Line Break, HPCF Diesel Generator Failure	6.3-64
Figure 6.3-47	Water Level Inside Shroud Following a Core Flooder Line Break, HPCF Diesel Generator Failure	6.3-64
Figure 6.3-48	Water Level Outside Shroud Following a Core Flooder Line Break, HPCF Diesel Generator Failure	6.3-65
Figure 6.3-49	Vessel Pressure Following a Core Flooder Line Break, HPCF Diesel Generator Failure	6.3-65
Figure 6.3-50	Flow Out of Vessel Following a Core Flooder Line Break, HPCF Diesel Generator Failure	6.3-66
Figure 6.3-51	Flow Into Vessel Following a Core Flooder Line Break, HPCF Diesel Generator Failure	6.3-66

List of Figures (Continued)

Figure 6.3-52	Peak Cladding Temperature Following a Core Flooder Line Break, HPCF Diesel Generator Failure	6.3-67
Figure 6.3-53	Water Level in Fuel Channels Following a Bottom Drain Line Break, HPCF Diesel Generator Failure	6.3-67
Figure 6.3-54	Water Level Inside Shroud Following a Bottom Drain Line Break, HPCF Diesel Generator Failure	6.3-68
Figure 6.3-55	Water Level Outside Shroud Following a Bottom Drain Line Break, HPCF Diesel Generator Failure	6.3-68
Figure 6.3-56	Vessel Pressure Following a Bottom Drain Line Break, HPCF Diesel Generator Failure	6.3-69
Figure 6.3-57	Vessel Pressure Following an RHR/LPFL Injection Line Break, HPCF Diesel Generator Failure	6.3-69
Figure 6.3-58	Flow Into Vessel Following a Bottom Drain Line Break, HPCF Diesel Generator Failure	6.3-70
Figure 6.3-59	Peak Cladding Temperature Following a Bottom Drain Line Break, HPCF Diesel Generator Failure	6.3-70
Figure 6.3-60	Water Level in Fuel Channels Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure	6.3-71
Figure 6.3-61	Water Level Inside Shroud Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure	6.3-71
Figure 6.3-62	Water Outside Shroud Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure	6.3-72
Figure 6.3-63	Vessel Pressure Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure	6.3-72
Figure 6.3-64	Flow Out of Vessel Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure	6.3-73
Figure 6.3-65	Flow Into Vessel Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure	6.3-73
Figure 6.3-66	Peak Cladding Temperatures Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure	6.3-74
Figure 6.3-67	Normalized Core Flow Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure (Based on Bounding Values)	6.3-74
Figure 6.3-68	Minimum Critical Power Ratio Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure (Based on Bounding Values)	6.3-75

List of Figures (Continued)

Figure 6.3-69	Water Level in Fuel Channels Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure (Based on Bounding Values).....	6.3-75
Figure 6.3-70	Water Level Inside Shroud Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure (Based on Bounding Values).....	6.3-76
Figure 6.3-71	Water Level Outside Shroud Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure (Based on Bounding Values).....	6.3-76
Figure 6.3-72	Vessel Pressure Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure (Based on Bounding Values).....	6.3-77
Figure 6.3-73	Flow Out of Vessel Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure (Based on Bounding Values).....	6.3-77
Figure 6.3-74	Flow Into Vessel Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure (Based in Bounding Values).....	6.3-78
Figure 6.3-75	Peak Cladding Temperature Following a Main Steamline Break Outside Containment, HPCF Diesel Generator Failure (Based on Bounding Values).....	6.3-78
Figure 6.4-1	Plant Layout	6.4-13
Figure 6.5-1	Standby Gas Treatment System P&IDs (Sheets 1–2)	6.5-16
Figure 6.5-2	Secondary Containment Pressure Transient After Design Basis LOCA	6.5-17
Figure 6.7-1	Nitrogen Supply System P&IDs (Sheets 1-2).....	6.7-6